

**Mandatory Language for a Maximum Contaminant Level Violation
MCL, SINGLE SAMPLE / NITRATE**

The Texas Commission on Environmental Quality (TCEQ) has notified the PWS TX2420002 - WHEELER MUNICIPAL WATER SYSTEM public water system that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for nitrate. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for nitrate to be 10 milligrams per liter (mg/L) based on a single sample and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for nitrate indicates a compliance value in quarter 1 of 2024 of 11 mg/L.

Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome. If your child is under the age of six months, the child **must** be given an alternative water supply for any consumption. Boiling the affected water is **not** an effective treatment for nitrate removal.

Most consumers do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you. At this time, the health effects to fetuses of pregnant women are unclear. If you are pregnant, you may also choose to use an alternative source of water for drinking and cooking purposes.

We are taking the following actions to address this issue:

Wheeler Water Department is testing all water wells to verify which, if any, wells have excessive Contaminant Level (MCL) of nitrate. The Reverse Osmosis Plant for the City's Water will also undergo inspection to verify all equipment and levels are at proper operational requirements and water samples will be taken for testing to ensure nitrate levels are below state required levels. Furthermore, the City Water Department will be monitoring water samples on an ongoing basis to ensure safe levels have been secured and remain safe for the public's consumption.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter contact:
Wheeler City Hall
501 S. Alan Bean Blvd.
Wheeler, TX.
806-826-3222

Posted/Delivered on: February 9, 2024